



# CERTIFICATE OF CONFORMITY

According to

## EMC Directive of 2014/30/EU

**Product:** HMI (Human Machine Interface)

**Type Designation:** mTV-1xx, mTV-100, mTV-101, mTV-100WK, cMT-HD, cMT-SVR-1xx, cMT-SVR-101, cMT-SVR-100WK, cMT-SVR-100, cMT-G05 (x=0-9, A-Z, blank or dash)

**Brand Name:** Weintek, EasyView, Weinview

**Applicant:** Weintek Labs., Inc.

**Applicant Address:** 3F, No. 910, Zhongzheng Rd., Zhonghe Dist., New Taipei City, Taiwan

The following standards were applied:

EN 55032: 2015 + AC: 2016, Class A

CISPR 32: 2015

Detailed specifications of the tested and certified product are shown in the following Test Report:

Test Report No: WD-EE-R-200027-A0

Issued Date: Feb. 06, 2020

The Certificate of Conformity (COC) is issued on a voluntary basis according to the Directive 2014/30/EU relating to Electromagnetic Compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification.



Ken Huang / Authorized Signatory

**Wendell EMC & RF Laboratory**

6F, No. 188, Baoqiao Road, Xindian District 231, New Taipei, Taiwan

TEL: +886-2-2917-5770 FAX: +886-2-2914-6763



# CERTIFICATE

**Issued Date: Feb. 04, 2020**  
**Report No. : 12A153R-ITCEP11V03**

This is to certify that the following designated product

**Product** : HMI (Human Machine Interface)  
**Trade name** : EasyView · WeinView · Weintek  
**Model Number** : mTV-100, mTV -101, mTV -1xx, cMT-SVR-100, cMT-SVR -101, cMT-SVR -1xx, mTV-100WK, cMT-SVR-100WK, cMT-HD, cMT-G05 (x=0-9, A-Z, blank or dash; for the software version or the appearance and color of the product may be different. No impact safety related critical components and constructions.)  
**Company Name** : Weintek Labs.,Inc.

This product, which has been issued the test report listed as above in DEKRA Testing and Certification Co., Ltd. Laboratory, is based on a single evaluation of one sample and confirmed to comply with the requirements of the following EMC standard.

<b>EN 55022: 2010+AC: 2011, Class A</b>	<b>EN 55024: 2010+A1: 2015</b>
<b>EN 61000-3-2: 2014</b>	<b>IEC 61000-4-2 Ed. 2.0: 2008</b>
<b>EN 61000-3-3: 2013</b>	<b>IEC 61000-4-3 Ed. 3.2: 2010</b>
<b>AS/NZS CISPR 22: 2009+A1: 2010</b>	<b>IEC 61000-4-4 Ed. 3.0: 2012</b>
	<b>IEC 61000-4-5 Ed. 3.1: 2014 + A1:2017</b>
	<b>IEC 61000-4-6 Ed. 4.0: 2013</b>
	<b>IEC 61000-4-8 Ed. 2.0: 2009</b>
	<b>IEC 61000-4-11 Ed. 2.1: 2004 + A1:2017</b>

TEST LABORATORY

Vincent Lin / Director

**DEKRA Testing and Certification Co., Ltd.**

No. 5-22, Ruishukeng, Linkou Dist., New Taipei City 24451, Taiwan (R.O.C.)  
TEL: +886-2-8601-3788 FAX: +886-2-8601-3789 Email: [info.tw@dekra.com](mailto:info.tw@dekra.com) <http://www.dekra.com.tw>